



Garden State Laboratories, Inc.

Report Date: 06/02/2023

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Lakeland Andover School
20 Jefferson Street

Newton, NJ 07860

Attention: J. Berghoff

Laboratory Director:

Client Number: LAK03

Sample ID: Kirchen Faucet Lab Sample ID: 230523050-01
Site: Collection Date/Time: 05/23/2023 07:00
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	06/01/23 10:48	

Sample ID: Mens Bathroom Lab Sample ID: 230523050-02
Site: Collection Date/Time: 05/23/2023 07:05
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	06/01/23 10:51	

Sample ID: Womens Bathroom Lab Sample ID: 230523050-03
Site: Collection Date/Time: 05/23/2023 07:10
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	0.00151 mg/l	0.015	0.00100	0.00032	20044	06/01/23 10:54	

Sample ID: Water Cooler (Main Office) Lab Sample ID: 230523050-04
Site: Collection Date/Time: 05/23/2023 07:15
Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	0.00158 mg/l	0.015	0.00100	0.00032	20044	06/01/23 10:57	



Garden State Laboratories, Inc.

Sample ID:	Custodial Closer POE	Lab Sample ID:	230523050-05							
Site:		Collection Date Time:	05/23/2023 07:25							
Matrix:	Potable water	Sample Type:	Grab							
Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	06/01/23 11:00	

Sample ID:	Boiler Room Sink	Lab Sample ID:	230523050-06							
Site:		Collection Date Time:	05/23/2023 07:20							
Matrix:	Potable water	Sample Type:	Grab							
Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	< 0.00100 mg/l	0.015	0.00100	0.00032	20044	06/01/23 11:11	

*DF=Dilution factor; <=less than. MCL=Maximum Contaminant Level. Rep. Limit=Reporting Limit.
MDL=Method Detection Limit. SM YR=Standard Methods Publication Year. and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11530 and PADEP #68-03680.*

